

**TO:** Prospective Bidders

**FROM:** Office of Facilities Planning & Construction  
 City College of San Francisco,  
 50 Phelan Ave. S142  
 San Francisco, CA 94112

**Project Manager:** David Liggett, AIA, Architect, Director Facilities Planning & Construction

**Phone:** (415) 239-3047, **cell:** (415) 505-7320, **e-mail:** dliggett@ccsf.edu

**PROJECT:** Soccer Practice Field Project - Ocean Campus - Rebid  
 50 Phelan Avenue  
 San Francisco, CA 94112

**BID DATE:** August 19, 2010 at 10:00 AM

**BID LOCATION:** Conference Room, ground floor, Health and Wellness Center

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents as noted below. In the case of difference with previous addenda, this addendum takes precedence. It is the responsibility of the Contractor to notify all parties from whom he accepts proposals for all changes in the Contract Documents covering this project. All other conditions remain unchanged. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

| Item: | Reference:   | Scope:  |
|-------|--|---|
| 1     | Question:<br>Two pre-bid meetings were held. 7/9/2010 and 8/12/2010. Does attendance at either meet the requirement for a bidder to have attended the mandatory pre-bid meeting? | Yes. Attendance at <b>either</b> of the pre-bid meetings meets the mandatory requirement. Attendance at only <b>one</b> of the meetings is required. Pre-bid sign in sheets for both meetings are attached.   |
| 2     | Question:<br>Is the synthetic turf included in the bid?  | No.   |
| 3     | Invitation to Bid  | On the Invitation to Bid in the description of the scope of the work, delete: <del>new field turf</del> and replace with new wording: <b>lighting and power.</b>  |
| 4     | Addendum 2, item 4 and Project Manual 01561 Storm Water Pollution Prevention, erosion and Sediment Control   | Delete: <del>The Owner (School District) will be responsible for the new requirements that become effective July 1, 2010,</del><br>And replace with new wording: <b>Contractor responsible for storm water pollution prevention, erosion and sediments control. Contractor to assist the District with preparing, submitting and procuring required permit. Contractor to assist the District with monitoring and required reporting. AGS Engineers is determining risk level, testing and monitoring protocols to expedite preparation and submission of permit.</b> |
| 5     | Addendum 2, item 8 Drawing L1.00 Demolition Plan and Drawing E1.01 Lighting Plan   | Delete: <del>Currently there are two (2) PG&amp;E Power Poles at the southeast corner of the site that interfere with the scope of this work as designed. CCSF is currently working with PG&amp;E to have these relocated.</del><br>And replace with new wording: <b>Contractor to contact PG&amp;E for direction on relocation of two (2) power poles and relocation of one (1) guy-wire pole. Contractor to relocate (2) power poles, (1) guy-wire pole and remove one (1) un-used power pole. Contractor prior to work is to</b>                                   |

|   |   |  |
|---|---|--|
|   |   | <b>identify existing underground utilities and future utility locations for coordinating location of pole installations.</b>   |
| 6 | Drawing L1.00 Demolition  | Note 13: remove tree. Add: <b>removal on one (1) additional pine tree which is dead and located next to the existing football play clock.</b>  |
| 7 | Drawing L3.01 Irrigation Plan Legend  | Clarify: 30 station pedestal mount irrigation controller: Rainmaster Evolution (DX30-SPED-DX) with radio control (RADIO-KIT) and antenna (EV-ANT-FD-KIT)   |
| 8 | Addendum 2, item 9<br>Drawing L1.00 Demolition Plan   | Delete: Clarification: <del>The existing temporary fence, k-rail and base rock stockpile is the responsibility of another contractor and shall not be included in this scope of work.</del> And replace with new wording. <b>Existing temporary fencing, k-rail and steel plate will be removed prior to work by previous contractor. Bidder (this contract) to remove base rock stockpile and dispose off-site. Bidder (this contract) to include new temporary construction barricade fencing.</b>   |
| 9 | Drawing C1.01 Civil notes and Symbols, Note 10<br>Responsibility for location of existing underground utilities | At note 10, revise as follows: .....accuracy or completeness of the information shown. The Contractor shall notify utility companies at least three (3) working days in advance of construction to field locate utilities. Call Underground Service Alert (U.S.A.) at 800-227-2600. It shall be the responsibility of the contractor to determine the existence and location of those utilities shown on these plans or indicated in the field by locating services. <b>The procurement of underground locating services and cost for providing locating services shall be the responsibility of the Contractor.</b> Additional costs..... |

Attachments.

1. Pre-bid meeting sign in sheet dated 7/9/2010 (2 pages)
2. Pre-bid meeting sign in sheet dated 8/12/2010 (1 page)

**END of ADDENDUM NO. 6**

| Name                           | Company                             | Address   | Phone           | SBE "yes" or "no" |
|--------------------------------|-------------------------------------|---|-----------------|-------------------|
| Slobodan Gabels<br>Tomo Gabels | Gabels Paving, Inc                  | 12340 Saratoga Sunnyvale<br>Saratoga, Ca. 95070 | 408 253-4777    | YES               |
| Michael Crowley                | D.C. JENSEN & SONS                  | 1520 Fourth St<br>Berkeley, CA 94710            | 510-809-3433    | NO                |
| KANDY C HALL                   | ROBERT A. BOTHAMMINK                | 650 QUINN AVE<br>SAN JOSE, CA 95112             | 408-279-2277    | NO                |
| GARY POLSON                    | INTERSTATE GRADING<br>& PAVING INC. | 128 S. MAPLE AVE<br>SO. SAN FRANCISCO, CA 94060 | 650-952-7333    | NO                |
| KEVIN ROWE                     | GHILLOTTI BROS.                     | 525 SACORY ST,<br>SAN RAFAEL, CA 94901          | (415) 760-0592  |                   |
| Erik Alderson                  | AGS, INC.                           | 5 Freeborn St.<br>San Francisco, CA             | (415) 777-2166  | N/A               |
| JAMES INGELS                   | RHAA                                | 323 GARY ST #602<br>SAN FRANCISCO 94102         | 415.861.7900    | N/A.              |
| JUANITA DOUGLAS                | KCA<br>ENGINEERS                    | 318 BEANNAN ST<br>S.F. CA 94107                 | 415<br>546-7111 | YES               |

GRADE BARBA ASIAN INC. 1167 MISSION ST.  
SF, CA 94103

(415) 928-5910 N/A



